



DEPORTED PROBE(S) TEMPERATURE

IoT sensor



CFG-APP



Features

The TMxD can monitor one to two remote temperature sensors -55°C | +125°C.

It is commonly deployed in buildings, energy installations and cold chain control.

The measurements are regularly transmitted by radio (Sigfox or LoRa technology) and the configuration is done from the tools of the ATIM suite locally or remotely.

Compatible with the computer and mobile versions of the IoT web platform, data visualization, remote parameterization of the sensor and the configuration of alerts according to predefined thresholds are made possible in a few clicks.

- Range : -55°C to +125°C for TMxD
-196°C to +150°C for TMxP-CRYO
- Precision : +/- 0.5°C between -10°C to +85°C for TMxD
+/- 0,15°C between -25°C to +70°C for TMxP
- IP65 protection rating
- Autonomy > 10 years*
- Interchangeable batteries
- Setup via USB, downlink or mobile app
- Redundancy of data and datalogging modes
- Visual signal showing network quality and sensor correct connection
- Plug & Play

References

Part number	Technology	
ACW/TM1D	Sigfox	LoRaWAN
ACW/TM2D	Sigfox	LoRaWAN
ACW/TM0P	Sigfox	LoRaWAN
ACW/TM1P	Sigfox	LoRaWAN
ACW/TM2P	Sigfox	LoRaWAN
ACW/TM1P-CRYO	Sigfox	LoRaWAN
ACW/TM2P-CRYO	Sigfox	LoRaWAN

* The autonomy of a product depends on several external factors (ambient temperature and humidity, transmission frequency, network quality, etc.). Subject to environmental conditions

**Available with a subscription to the Atim Cloud Wireless™ web platform.

COMPLY WITH SANITARY STANDARDS



Smart Building



Smart City



Smart Industry

- Monitor the temperature at the inlet to the outlet of the domestic water network.
- Comply with legislation requiring regular monitoring of the water temperature, which must be between 55 ° C and 60 ° C in all public buildings.
- Limit the legionella risk.



- Guarantee compliance with the cold chain and hygiene rules.
- Control the temperature of your cold rooms, refrigerated banks, refrigerated trucks.
- Keep the data transmitted in the event of an inspection.
- Control and avoid any health risk.

- Monitor the water temperature at the outlet of the network.
- Avoid overheating the water, it is advisable not to heat above 60 ° C to avoid the risk of severe burns.
- Reduce the energy bill by maintaining an optimal and constant temperature.

